

Record of Water Well

Indiana Department of Natural Resources

Reference Number	Driving directions to well	Date completed
410206		Oct 10, 2007

Owner-Contractor	Name	Address	Telephone
Owner			
Driller	C & J WELL DRILLING CO	PO BOX 747 BROWNSBURG, IN	(317) 892-2100
Operator	DON BAUGHMAN	License: 178	

Construction Details

Well	Use: Home	Drilling method: Rotary	Pump type: Submersible
	Depth: 37.0	Pump setting depth: 0.0	Water quality: CLEAR
Casing	Length: 35.0	Material: PVC	Diameter: 5.0
Screen	Length: 2.0	Material: STAINLESS ST	Diameter: 5.0 Slot size: .050

Well Capacity Test	Type of test: Air	Test rate: 30.0 gpm for 1.0 hrs.	Bail Test rate: gpm for hrs.
	Drawdown: 0.0 ft.	Static water level: 20.0 ft.	Bailer Drawdown ft.

Grouting Information	Material: BENTONITE	Depth: from 0.0 to 20.0
	Installation Method: PRESSURE	Number of bags used: 5.0

Well Abandonment	Sealing material: HOLEPLUG	Depth: from 0 to 60
	Installation Method: HAND	Number of bags used: 8.0

Administrative	County: MARION	Township: 15N Range: 3E
	Section: NE of the NW of the SW of Section 5	Topo map: INDIANAPOLIS WEST
	Grant Number:	
	Field located by: DRILLER	on: Oct 10, 2007
	Courthouse location by:	on:
	Location accepted w/o verification by:	on:
	Subdivision name:	Lot number:
	Ft W of EL:	Ft N of SL:
	Ground elevation: 718.0	Depth to bedrock:
	UTM Easting: 565893.0	UTM Northing: 4402521.0
		Ft E of WL: 900.0
		Ft S of NL: 1800.0
		Bedrock elevation:
		Aquifer elevation: 681.0

Well Log	Top	Bottom	Formation
	0.0	15.0	CLAY
	15.0	37.0	SAND & GRAVEL

